

Construction of the Flight Projects Building  
Solicitation No. NNG12412656E  
Questions and Responses  
July 26, 2012

1. Question: *Roughly how many linear feet of fence and gates there were. It said in the description that there was security fencing, but the documents that I was able to download only talked about ornamental fencing.*

**Response:** The ornamental fence requirements are for the garbage dumpsters enclosure area as indicated in drawing A-731 and under Part 2 of specification section 32 31 19. The Government does indicate security fencing, but this security fencing is temporary project area fencing, which is typically a 6' high chain link fence used to control access to the project construction area.

2. Question: *Reference drawing C-105, M-505: Sheet C-105 references a detail on M505 for CWS/CWR tie into existing however there is no detail on sheet M505. Please provide detail and sizing of these lines.*

**Response:** There is a detail provided. Please refer to detail no. 7 labeled “underground chilled water pipe connection” in the upper left hand corner of drawing M-505.

3. Question: *This project is solicited as a sealed bid (IFB) and solicitation page 68, Section M.2 52.214-19 states that the government will evaluate bids “considering only price and the price-related factors”. So could you confirm that the information on BIM experience of personnel mentioned in “Attachment 4 – Construction Building Information Modeling”, page 1, paragraph 1.3, will not be required with the bid submission?*

**Response:** Confirming that the information on the BIM personnel will not be required with the bid submission. This information will be required by the apparent low bidder prior to contract award.

**{End of Questions/Responses}**